


NOTE:

1. CENTERING PLATE TO INCLUDE THE FOLLOWING INFORMATION
 - A. MANUFACTURER'S NAME
 - B.  DIRECTION TO CLOSE, NO. OF TURNS.
 - C. SIZE & CLASS.
 - D. DIRECTION OF OPENING.
 - E. TORQUE LIMITER
2. DEZURICK VALVE OR APPROVED EQUAL (OAE).
3. TORQUE LIMITING DEVICE SHALL BE HERMETICALLY SEALED IN C.I. HOUSING, PERMANENTLY LUBRICATED, FACTORY SET TO TRIP BETWEEN 200 – 220 FT. LBS., COATED INSIDE AND OUT WITH 2-PART EPOXY AND ROTATION DIRECTION PERMANENTLY SHOWN; AS MANUFACTURER BY ANNSPACH CONTROLS CO., OR APPROVED EQUAL.

GENERAL NOTE:
 THE CONTRACTOR SHALL USE ONLY THOSE DETAILS THAT ARE APPLICABLE TO THE PROJECT AND AS DIRECTED BY THE CITY ENGINEER.

BUTTERFLY VALVE & VALVE BOX DETAIL FOR
VALUES GREATER THAN 12" Ø PIPE SIZE
 N.T.S.

F:\work\ALL\CAD-DWG\STANDARDS\CMB_STANDARD_DETAILS\Public Works Manual\CMB Water Details