



NOTES:

1. THE FIRE HYDRANT LOCATION SHOULD BE PLACED NO CLOSER THAN 10 FEET TO EDGE OF DRIVEWAY.
2. THE DIMENSION OF THE R/W TO THE CENTER OF THE FIRE HYDRANT SHALL BE 9 INCHES. WHEN THE SIDEWALK IS 5 FEET, MUST TRY TO PLACE FIRE HYDRANT IN A LOCATION WHERE THERE IS NOT A BUILDING STRUCTURE IN THE RIGHT-OF-WAY LINE.
3. THE DIMENSION OF THE R/W TO THE CENTER OF THE FIRE HYDRANT SHALL BE 18 INCHES WHEN THE SIDEWALK IS GREATER THAN 5 FEET.

FIRE HYDRANT LOCATED
CLOSE TO DRIVEWAY
N.T.S.

F:\work\\$\ALL\CAD-DWG\STANDARDS\CMB_STANDARD_DETAILS\Public Works Manual\CMB Water Details