

NOTES:

- 1. AIR RELEASE RISERS AND VALVE BOX RISERS SHALL BE PLACED AND MAINTAINED IN VERTICAL POSITION.
- 2. ALL EXPOSED METALLIC THREADS ARE TO BE COATED WITH BITUMASTIC PAINT AFTER INSTALLATION IF ITS NOT BRASS

TYPICAL FLUSHING VALVE OUTLET N.T.S.

F:\WORK\\$ALL\CAD-DWG\STANDARDS\CMB_ STANDARD_DETAILS\Public Works Manual\CMB Water Details



02/01/2010

REVISED TITLE: 10/04/2011

WATER DETAILS NO. 5
TYPICAL FLUSHING VALVE OUTLET

WS34 SHEET 36 OF 37