



- GENERAL DETAILS:
- 1-PROVIDE SHOP DRAWINGS OF STRUCTURES.
 - 2-PRECAST CONCRETE MANHOLES SHALL CONFORM TO ASTM C478, SHALL BE TYPE II ACID RESISTANT CEMENT AND SHALL MAINTAIN A MINIMUM COMPRESSIVE STRENGTH OF 4000 PSI IN 28 DAYS.
 - 3-REFER TO FODT INDEX 200 FOR ADDITIONAL DETAILS AND SPECIFICATIONS.
 - 4-ALL REINFORCING BARS SHALL BE ASTM A615 GRADE 60, ALL COVER SHALL BE 3 INCHES MINIMUM.
 - 5-NO WELDS ON THE TOP 15 FEET OF THE WELL CASING ARE ALLOWED.
 - 6-GRATE TO BE CORROSION RESISTANT IN A SALT WATER ENVIRONMENT.

RETENTION BOX FOR
DRAINAGE WELL SECTION
N.T.S.

F:\WORK\ALL\CAD-DWG\STANDARDS\CMB_STANDARD_DETAILS\Public Works Manual\CMB Drainage Details